

May 27, 2009

POLYLOK, INC.
PETER GAVIN
3 FAIRFIELD BLVD
WALLINGFORD CT 06492

Re: Description: **SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER (see also SEWAGE TREATMENT TANKS) ***
Manufacturer: POLYLOK, INC.
Product Name: PL-68 EFFLUENT FILTER
Model Number(s): 30130
[PREVENTS ANY PARTICLE > 1/16 IN. FROM PASSING THROUGH FILTER]
Product File No: 20090207

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of January 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.

This approval supersedes the approval issued on 1/22/2004 under product file number 20030593. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number #20030593.

*** TO ASSIST USERS IN ON-LINE SEARCHES FOR COMMERCE PLUMBING PRODUCT APPROVALS AND TO BETTER DESCRIBE THIS PART/DEVICE, AS OF THE DATE OF THIS COMMUNICATION, THIS PRODUCT TYPE DESCRIPTION HAS BEEN CHANGED FROM SEWAGE TREATMENT APPARATUS (STA) TO SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER (STAF); SEE ALSO http://commerce.wi.gov/php/sb-ppalopp/prodcode_alpha_list.php.**

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov